

**COUNTY OF DELAWARE
ADDENDUM # 2
HUNT CLUB BOILER REPLACEMENT (eDPW-090424)**

The County of Delaware Invitation to Bid for: **HUNT CLUB BOILER REPLACEMENT (EDPW-090424)**. Bid proposals will be received electronically via PennBid Program (<https://pennbid.bonfirehub.com>) by the Department of Central Purchasing on Wednesday, September 4, 2024 @ 11:00 a.m.

*****BID QUESTION, CLARIFICATIONS AND ANSWERS*****

Questions #1: Is there an estimated value for this project?

Answer: The County does not publish this information.

Questions #2: Please confirm no piping insulation is required for this project. We noticed that most of the existing piping is not insulated.

Answer: Insulation requirement is referenced in Advertisement for Bid (page 2): "Pipe insulation is required." The scope of insulation is at all exposed new and existing hot water piping within the basement.