

COUNTY OF DELAWARE
ADDENDUM # 1
LITTLE FLOWER PARK WATER LINE CDBG PROJECT #50-85A

The County of Delaware advertised on the County of Delaware's website/PennBid and in the Philadelphia Inquirer and Daily Times newspapers the Invitation to Bid for: LITTLE FLOWER PARK WATER LINE CDBG PROJECT #50-85A on Friday, March 13, 2026. Submissions are to be received via PennBid on Wednesday, April 8, 2026 @ 11:00 a.m.

*****BID QUESTIONS, CLARIFICATIONS AND ANSWERS*****

DRAWING CSD-2 HAS BEEN UPLOADED.

Question #1: Requesting engineer's estimate or budget for construction.?

Answer: The County is not disclosing the engineers estimate.

Question #2: Is union labor required?

Answer: The project is subject to PA Prevailing Wage.

Question #3: Can you confirm that Aqua will be supplying and setting the meter pit required and contractor just needs to proceed from that point with water service.

Answer: The meter pit is required to be provided by the contractor. (Refer to attached Drawing CSD-2). Aqua will connect from the road to meter pit. (Refer to attached CSD-2)

Question #4: Would you be willing to add the option of also quoting plastic service line as an alternative.

Answer: 2" SDR-9 – Polyethylene Pipe is acceptable. A line has been added to reflect this as an Alternate. Plus input a negative value to reflect the cost difference between the requested materials, if lower.