

COUNTY OF DELAWARE

ADDENDUM # 1

COUNTY OF DELAWARE BRIDGE MAINTENANCE AND REPAIRS FOR BRIDGES #135 AND #243 (eDPW-080526)

The County of Delaware advertised on the County of Delaware's website/PennBid and in the Philadelphia Inquirer and Daily Times newspapers the Invitation to Bid for: COUNTY OF DELAWARE BRIDGE MAINTENANCE AND REPAIRS FOR BRIDGES #135 AND #243 (eDPW-080526) on Tuesday, June 23 and Friday June 26, 2026. Submissions are to be received via PennBid on Wednesday, August 5, 2026 @ 11:00 a.m.

*****BID QUESTIONS, CLARIFICATIONS AND ANSWERS*****

Questions #1: There is an unidentified utility line in front of the abutment at bridge #135, it appears to be in a temporary condition. Can clarification be provided on the utility owner and if additional utility coordination may be needed that may affect the schedule.

Answer: The utility under the 4th Avenue Bridge (Bridge 135) is a temporary bypass for the sanitary sewer. The existing Sanitary Sewer runs parallel to the creek, to the west of the existing bridge.

It is not anticipated that this will affect this project's schedule, as all work involved with this bridge is with the superstructure, and no work is scheduled within the waterway.

Questions #2: In your instructions you mention the Contractor Statement sheet and financial sheet required to bid. Can you clarify if you want the whole packet or just section A & B?

Answer: Please submit the AIA Document A305 - 2020, Contractor's Qualification Statement with all sections.